MAHANAND DAIRY

26856071/585

Fax: 26856596

bu: 50820200/01

M MAHARASHTRA RAJYA SAHAKARI DUDH MAHASANGH MARYADIT Unit No. 12, Aarey colony, Western Express Highway, Goregaon (E), Mumbai-400065

ENQUIRY

Ref. No. MND/6/ENGG/2024-25/2154

Date: -15 /10/2024

Under Postal Certificate

TO,					
	M/S.				
	IVI/ 5				
					_

Dear Sir.

Kindly submit your lowest offer for the following items mentioned below. Quotations may please be sent to us on or before - 25/10/2024. Quotation received after the due date mentioned herein will not be considered. Quotation should be send in sealed cover duly marked as Quotation for :- Replaceament of -18° C (7 Ton) cold store Anti chamber door . Quotation Received on Email will not be considered.

Sr. No	Description	Quantity Required
1	Supply,Installation & commissioning of Anti chamber Door for -18° C (7 Ton) cold store with below mentioned specifications.	1 JOB
	 Door Dimension :34" x 78" inches. Door frame Dimension 46" x 122" inches Cladding: PPGI inside and PPGI outside. Insulation: 125 mm thick eco friendly Cyclopentane Polyurethane foam, sandwiched between 0.50 mm PPGI sheets PUF Density: 40 kgs +/- 2 KG/M3 K Factor: 0.021 to 0.023. Fire Retardent property: Self – extinguishing With ACCESSORIES Door Handle with lock b) Door closure C) Door heater d) Door Gasket e) Sweeping Gasket Floor Thickness: 5 mm Aluminum chequered plate 	
	Terms and Conditions :-	
	 Party can visit at Mahanand Dairy, Goregaon (E) Mumbai if reqired Party should confirm excat measurement before providing in Quotation by visiting the plant. 	
	Party should supply,Install & commission the door with proper fitting with zero leakage from Door Gasket. A least party should be given us one year door warrenty.	1
	 4) At least party should be given us one year door warrenty. 5) The rate should be quoted with labour, Equipments, taxes and Duties etc. NOTE:-Enquiry copy available at our website (www.mahanand.in 	

Dy Manager (Engg.)

Operation Head

Vhu