



MAHANAND DAIRY

Ph: 26856360/61
26856071/585
Fax: 26856596

MRSDMM MAHARASHTRA RAJYA SAHAKARI DUDH MAHASANGH MARYADIT
Unit No. 12, Aarey colony, Western Express Highway, Goregaon (E), Mumbai-400065

ENQUIRY

Ref.No.MND/6/ENGG/2023-24 /1495

Date: - 12/09 /2023

Under Postal Certificate

TO,

M/S. _____

Dear Sir,

Kindly submit your lowest offer for the following items mentioned below. Quotations may please be sent to us on or **before 22/09/2023** Quotation received after the due date mentioned herein will not be considered. Quotation should be send in sealed cover duly marked as **Quotation for :- Comprehensive Annual Maintenance of Milk Product Stand Alone Refrigeration System.**

Sr. No	Description	Quantity Required
1	<p>Comprehensive Annual Maintenance of Milk Product Chiller Cold room Unit & Blast Chiller room as per Attached (Backside) Annexure at Mahanand Dairy Goregaon (East), Mumbai – 400 065.</p> <p>Terms and Conditions :-</p> <ol style="list-style-type: none">1) The rate should be quoted with labour, Equipments, taxes and Duties etc.2) The online job completed as per norms of Quality Control and maintaining Hygienic condition.3) If necessary party may visit the site for assessing the quantum of work and can have the discussion for clarification if any.4) Party shall arrange for insurance etc., of his people employed for the work as per ESIC, Workman compensation Act and any other provision to meet. Statutory requirements of various Acts / Rules In case of an accident to any of his workers in his employment or agents during the period of Servicing, the office of the MRSDMM shall not bear any liability, whatsoever. The entire responsibility primary and final in this respect will be that of the party.5) Work should be planned and completed without disturbing routine a ctivity.6) The payment will be made in Advance, Half Yearly, after accepting Order & commitment of the work. <p>AMC EXPIRY DATE : 19.09.2023</p>	1 JOB

A/C Manager (Engg.)



ANNEXURE " A "

SCOPE FOR AMC OF CHILLER COLD ROOM UNITS & BLAST CHILLER ROOM UNITS

- 1) Monthly visit for visual inspection of Milk Product Chiller cold room Units & Blast Chiller room Units refrigeration system to maintain continuous Design temperature and to avoid any loss of Storage Milk Products due to temperature.
- 2) To check and service all the equipments connected to the Chiller cold room Units & Blast Chiller room Units refrigeration units every alternate month.
- 3) To attend break-down calls within 24 hrs. in Comprehensive CAMC period.
- 4) Checking of refrigeration system including indoor and outdoor units for proper functioning at all times .
- 5) Replacement / repairing of the defective or worn out parts at site / service station for maintaining proper working of the system to maintain specified temperature.
- 6) Replacements of the refrigerant gas, compressor oil, in the system for proper working of the system as and when required.
- 7) Replacement of parts due to normal wear and tear during normal operation of the system.
- 8) Compressor, condenser coils, thermostat, evaporator and defrosting system to be checked for proper working of the system.
- 9) Comprehensive Preventive Maintenance and servicing once in every three months.
- 10) Supplying electrical & mechanical spare parts which are part of the machine.
- 11) Checking the refrigerant piping for signs of leaks and repairing the leaks, if any.
- 12) Checking the machine, compressor and other drives for undue vibrations.
- 13) Cleaning the air filters, evaporator coil, and finned surface of the condenser with air blower.
- 14) Ensuring the condensate drain is not clogged.
- 15) Greasing of motor and blower bearings if required.
- 16) Checking tightness of all electrical connections and fuse links.


A/C MANAGER(ENGG.)